

Declaration of Conformity

Doc. No.: 202050DC46

To whom it may concern,

Frese A/S hereby declares that the product(s) stated below are in accordance with the directive and standards stated below.

Product(s): Frese Butterfly Valve Range DN50 to DN600

Directives:

- PED 2014/68/EC - Pressure Equipment Directive
 - Pressure Accessories
 - Article 4 § 3 – Not CE marked - (DN50, DN250, DN300)
 - Article 4 § 1.c.i - Category I, Fluid group 2 - (DN65 to DN200)
 - Article 4 § 1.c.ii - Category I, Fluid group 2 - (DN350 to DN600)
- ROHS 2011/65/EU - Restriction of the use of certain hazardous substances

Applied standards:

- Connection flange: ISO 7005.2
- Top Flange: ISO 5211
- Pressure testing: EN12266-1
- Leakage class: ISO 5208 Rate A (zero leakage)

All Frese products are manufactured and tested in accordance with the ISO 9001 quality system, which is reviewed by DNV-GL every 12 months.

For information on our products, please refer to our website www.frese.eu for the latest Technotes.

It is certified that the undersigned is an official representative for Frese A/S, and that the necessary quality controls have been performed to substantiate this certification.

Certified by:

Date of issue: 8th December 2020



Henrik Lillelund

Quality & Environmental Manager

