

Declaration of Conformity

Doc. No.: 201927DC20

To whom it may concern,

Frese A/S hereby declares that the product(s) stated below are in accordance with the directive and standards stated below.

Product(s): Frese OPTIMA Compact HCR DN50 to DN80

Directives:

- PED 2014/68/EU - Pressure Equipment Directive
 - Pressure Accessories
 - Article 4 § 1.c.i - Category I, Fluid group 2 - (DN50 to DN80)
- ROHS 2011/65/EU - Restriction of the use of certain hazardous substances

Applied standards:

- Valve connections: DIN/EN 1092-2
- Valve dimensions: EN558-1
- Pressure testing: EN12266-1
- Leakage class: EN 1349 Class IV


All Frese products are manufactured and tested in accordance with the ISO 9001 quality system, which is reviewed by DNV-GL every 12 months.

For information on our products, please refer to our website www.frese.eu for the latest Technotes.

It is certified that the undersigned is an official representative for Frese A/S, and that the necessary quality controls have been performed to substantiate this certification.

Certified by:

Date: 7th July 2019



Henrik Lillelund
Quality & Environmental Manager

