

## Declaration of Conformity

Doc. No.: 202347DC18

### To whom it may concern,

Frese A/S hereby declares that the product(s) stated below are in accordance with the directive and standards stated below.

**Product(s): Frese OPTIMA Compact EP Flange DN50 to DN200**

### Directives:

- PED 2014/68/EU - Pressure Equipment Directive
  - Pressure Accessories
  - Article 4 § 1.c.i - Category I, Fluid group 2 - (DN50 to DN200)
- ROHS 2011/65/EU - Restriction of the use of certain hazardous substances

### Applied standards:

- Valve connections: DIN/EN 1092-2
- Valve dimensions: EN558-1
- Pressure testing: EN12266-1
- Leakage class: EN 1349 Class IV


All Frese products are manufactured and tested in accordance with the ISO 9001 quality system, which is reviewed by DNV every 12 months.

For information on our products, please refer to our website [www.frese.eu](http://www.frese.eu) for the latest data sheets.

It is certified that the undersigned is an official representative for Frese A/S, and that the necessary quality controls have been performed to substantiate this certification.

### Certified by:

Date: 23<sup>rd</sup> November 2023



Henrik Lillelund

**Quality & Environmental Manager**

