

## Declaration of Conformity

Doc. No.: 202111DC09

### To whom it may concern,

Frese A/S hereby declares that the product(s) stated below are in accordance with the directive and standards stated below.

### Product(s): SIGMA Compact Flange DN50 to DN300

#### Directives:

- PED 2014/68/EU - Pressure Equipment Directive
  - Pressure Accessories
  - Article 4 § 1.c.i - Category I, Fluid group 2 - (DN50 to DN125 + DN150 PN16 + DN200 PN16)
  - Article 4 § 1.c.i - Category II, Fluid group 2 - (DN250 PN16 + DN300 PN16)
  - Article 4 § 3 – Not CE marked - (DN150 PN 25 + DN200 PN25)
  - Article 4 § 1.c.ii - Category I, Fluid group 2 - (DN250 PN25 + DN300 PN25)
- ROHS 2011/65/EU - Restriction of the use of certain hazardous substances

#### Applied standards:

- Valve connections: DIN/EN 1092-2
- Valve dimensions: EN558-1
- Pressure testing: EN12266-1
- Leakage class: EN 1349 Class IV


All Frese products are manufactured and tested in accordance with the ISO 9001 quality system, which is reviewed by DNV-GL every 12 months.

For information on our products, please refer to our website [www.frese.eu](http://www.frese.eu) for the latest Technotes.

It is certified that the undersigned is an official representative for Frese A/S, and that the necessary quality controls have been performed to substantiate this certification.

#### Certified by:

Date: 17<sup>th</sup> March 2021



Henrik Lillelund

**Quality & Environmental Manager**





Frese A/S - Sorøvej 8 - DK-4200 Slagelse - Tel: +45 58 56 00 00 - Fax: +45 58 56 00 91 – [www.frese.eu](http://www.frese.eu)

